



**Texas Department of Insurance**

**State Fire Marshal's Office**

Mail Code 112-FM, 333 Guadalupe • P. O. Box 149221, Austin, Texas 78714-9221

January 12, 2006

Mr. Jason Collier  
Fire Chief of Lake Cities FD  
3101 South Garrison  
Corinth, Texas 76210

**Place Code: Denton: 12140**

Dear Mr. Collier:

Insurance Services Office (ISO) has submitted a recommendation concerning your community's Public Protection Classification (PPC). Currently, the Community's Public Protection Classification rating is Class 6/9.

**Insurance Services Office is recommending that the classification be changed to a split Class 4/9, with an effective date of 06/01/2006.** The recommendation is based on a review of your community performed on 07/19/2005 and does include application of the Texas Addendum.

With a split Class 4/9, all class-rated properties located within 1000 feet of a fire hydrant and within 5 miles of a fire station will use Class 4. All class-rated properties located farther than 1000 feet of a fire hydrant and within 5 miles of a fire station will use Class 9.


Public Protection Classifications range from 1 (best) to 10 (worst).

We have reviewed the information provided and believe it is sufficient to grant approval. Enclosed is a PPC Submittal sheet indicating point totals for the major areas associated with the review. We will notify Insurance Services Office of our approval of the recommendation and of the 06/01/2006 effective date.

If you have any questions regarding this change, I may be reached at the address indicated above or by telephone at (512) 305-7941.

*Please make sure all community officials and residents within your district are notified of the new Public Protection Classification rating for your community, and the effective date.*

Sincerely,

  
Jesse James Williams  
Deputy State Fire Marshal  
PPC Oversight Representative

TEXAS DEPARTMENT OF INSURANCE

Approved

JAN 12 2006

State Fire Marshal

PPC Oversight Representative  
E-Mail: jesse.williams@tdi.state.tx.us